Date 29-6-2022 The Flamingo Boss. LTD

Equipment Register and Test Record

Inspection										Test						
			Frequency								Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0001	Letter N	N/A	Yearly	Yearly	N/A	✓	✓	✓	✓	N/A		>200			✓
0002	letter S	"	"	"	"	✓	✓	✓	✓	N/A		Lim		Visual	✓
0003	letter A	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0004	letter H	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0005	~~Number~~ letter B	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0006	Letter E	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0007	Letter V	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0008	Letter L	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0009	Letter B	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0010	letter Y	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0011	letter O	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0012	letter O	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0013	Number 9	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0014	Number 8	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0015	Number 7	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0016	Number 6	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0017	Number 5	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0018	Number 4	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0019	Number 3	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0020	Number 3	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0021	Number 2	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0022	Number 2	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0023	Number 1	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0024	Number 1	"	"	"	"	✓	✓	✓	✓	N/A		"		Visual	✓
0025	Ex lead	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓

244 items Tested by [signature]

C.S.R electrical Services.

Note: (✓) indicates pass, (X) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 29-6-2022 The Flamingo boss LTD

Equipment Register and Test Record

Inspection										Test						
			Frequency								Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0026	Ex lead	n/a	Yearly	Yearly	n/a	✓	✓	✓	✓	.09	✓	>200			✓
0027	Speaker Ref	"	"	"	"	✓	✓	✓	✓	Lim		>200			✓
0028	" "	"	"	"	"	✓	✓	✓	✓	Lim		>200			✓
0029	Magic Mirror 2	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0030	" Ex lead	"	"	"	"	✓	✓	✓	✓	.15	✓	>200			✓
0031	IEC lead	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0032	" "	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0033	" "	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0034	AC Adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0035	Triple Plug	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0036	Ex lead	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0037	IEC lead	"	"	"	"	✓	✓	✓	✓	.04	✓	>200			✓
0039	AC adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0040	BOSE adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0041	IEC lead	"	"	"	"	✓	✓	✓	✓	.8	✓	>200			✓
0042	IEC Socket	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0043	" LEAD	"	"	"	"	✓	✓	✓	✓	.05	✓	>200			✓
0044	Magic M2 TV	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0045	Ex lead	"	"	"	"	✓	✓	✓	✓	.04	✓	>200			✓
0046	AC adapter	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0047	" Lead	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0048	" adapter	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0049	" Lead	"	"	"	"	✓	✓	✓	✓	n/a		>200			✓
0050	IEC lead	"	"	"	"	✓	✓	✓	✓	.14	✓	>200			✓
0038	Triple plug	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓

Note: (✓) indicates pass, (✗) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 29-6-2022 The Flamingo bass Ltd

Equipment Register and Test Record

Inspection									Test						
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0051	IEC Lead	n/a	Yearly	Yearly	N/A	✓	✓	✓	✓	.17	✓	>200			✓
0052	AC adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0053	" "	"	"	"	"	✓	✓	✓	✓	N/A		Lim		Visual	✓
0054	" "	"	"	"	"	✓	✓	✓	✓	N/A		Lim		Visual	✓
0055	IEC Plug	"	"	"	"	✓	✓	✓	✓	.07	✓	>200			✓
0056	Ex lead 10	"	"	"	"	✓	✓	✓	✓	.50	✓	>200			✓
0057	" " "	"	"	"	"	✓	✓	✓	✓	.47	✓	>200			✓
0058	AC adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0059	" "	"	"	"	"	✓	✓	✓	✓	N/A		Lim		Visual	✓
0060	Ex lead	"	"	"	"	✓	✓	✓	✓	.10		>200			✓
0061	AC adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0062	IEC lead	"	"	"	"	✓	✓	✓	✓	Lim		>200			✓
0063	Ex lead	"	"	"	"	✓	✓	✓	✓	.09	✓	>200			✓
0064	Mixing Board	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0065	IEC lead	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0066	Fan	"	"	"	"	✓	✓	✓	✓	.18	✓	>200			✓
0067	Ex lead	"	"	"	"	✓	✓	✓	✓	.01	✓	Lim		USB's	✓
0068	AC/DC adapter	"	"	"	"	✓	✓	✓	✓	N/A		Lim			✓
0069	AC adapter	"	"	"	"	✓	✓	✓	✓	n/a		Lim		Visual	✓
0070	" "	"	"	"	"	✓	✓	✓	✓	MΩ		>200			✓
0071	" " LED	"	"	"	"	✓	✓	✓	✓	MΩ		>200			✓
0072	RCF38 Speaker	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓
0073	"	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓
0074	"	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓
0075	"	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓

Note: (✓) indicates pass, (X) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 29-6-2022 the Flamingo Bess LED

Equipment Register and Test Record

Inspection						Test									
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0076	RCF38 Speaker	N/A	Yearly	Yearly	N/A	✓	✓	✓	✓	Lim		Lim		Visual	✓
0077	" "	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓
0078	Podium 1 L	"	"	"	"	✓	✓	✓	✓	N/A		>200			✓
0079	Podium 2 L	"	"	"	"	✓	✓	✓	✓	"		>200			✓
0080	IEC lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0081	" "	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0082	" "	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓
0083	Gig Bar	"	"	"	"	✓	✓	✓	✓	.41	✓	>200			✓
0084	Speaker Yamaha	"	"	"	"	✓	✓	✓	✓	.04	✓	>200			✓
0085	"	"	"	"	"	✓	✓	✓	✓	.04	✓	>200			✓
0086	IEC Lead	"	"	"	"	✓	✓	✓	✓	.07	✓	>200			✓
0087	" " Extension	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0088	LED) 7 B	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0089	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0090	" "	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0091	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0092	" " W	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0093	" " W	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0094	" " W	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0095	" " W	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0096	" " W	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0097	" " W	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0098	IEC lead	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0099	" "	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0100	LEDJ 7 W	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓

Note: (✓) indicates pass, (x) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 29-6-2022 The Flamingo Boss Ltd

Equipment Register and Test Record

Inspection									Test						
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0101	LED 7 W	nh	Yearly	Yearly	N/A	✓	✓	✓	✓	0.01	✓	>200			✓
0102	" "	"	"	"	"	✓	✓	✓	✓	0.01	✓	>200			✓
0103	" "	"	"	"	"	✓	✓	✓	✓	0.03	✓	>200			✓
0104	Spike IEC	"	"	"	"	✓	✓	✓	✓	.14	✓	>200			✓
0105	Ex lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0106	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0107	" "	"	"	"	"	✓	✓	✓	✓	.02	✓	>200			✓
0108	Ham Whirl 2	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0109	" " 1	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0110	ADJ Black 1	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0111	" " 2	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0112	Bose speaker 1	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0113	" " 2	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0114	DJ Stardoth	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0115	IEC lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0116	DJ Stardoth	"	"	"	"	✓	✓	✓	✓	.01	✓	>200			✓
0117	IEC Lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0118	Ex lead	"	"	"	"	✓	✓	✓	✓	.14	✓	>200			✓
0119	" "	"	"	"	"	✓	✓	✓	✓	.21	✓	>200			✓
0120	UV light	"	"	"	"	✓	✓	✓	✓	.01	✓	Lim			✓
0121	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	Lim			✓
0122	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	Lim			✓
0123	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	>200			✓
0124	Fusion Spot 1	"	"	"	"	✓	✓	✓	✓	.16	✓	>200			✓
0125	" " 2	"	"	"	"	✓	✓	✓	✓	.08	✓	>200			✓

Note: (✓) indicates pass, (x) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 29-6-2022 The Flamingo Boss Ltd

Equipment Register and Test Record

Inspection									Test						
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0126	Fusion LV 3	nk	Yearly	Yearly	N/A	✓	✓	✓	✓	·01	✓	>200			✓
0127	" 4	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0128	Vortex 2	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0129	Power Con lead	"	"	"	"	✓	✓	✓	✓	·06	✓	>200			✓
0130	Vortex 1	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0131	Power Con lead	"	"	"	"	✓	✓	✓	✓	·09	✓	>200			✓
0132	Fusion 1 W	"	"	"	"	✓	✓	✓	✓	·06	✓	>200			✓
0133	Fusion Spot 4	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0134	" 2	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0135	" 3	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0136	AC adapter	"	"	"	"	✓	✓	✓	✓	N/A		Lim		Visual	✓
0137	WiFi Adapter	"	"	"	"	✓	✓	✓	✓	"		Lim		Visual	✓
0138	" "	"	"	"	✓	✓	✓	✓	✓	"		Lim		Visual	✓
0139	LED 3 6/3	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0140	PEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0141	IEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0142	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0143	Haze Mach	"	"	"	"	✓	✓	✓	✓	·13	✓	>200			✓
0144	Strob light	"	"	"	"	✓	✓	✓	✓	Lim		Lim		Visual	✓
0145	Printer 3	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0146	" 2	"	"	"	"	✓	✓	✓	✓	·04	✓	>200			✓
0147	DJ Controller	"	"	"	"	✓	✓	✓	✓	·06	✓	>200			✓
0148	Printer 1	"	"	"	"	✓	✓	✓	✓	·01	✓	>200			✓
0149	TV	"	"	"	"	✓	✓	✓	✓	N/A		>200			✓
0150	AC adapter	"	"	"	"	✓	✓	✓	✓	N/A		>200			✓

Note: (✓) indicates pass, (X) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 30-6-2022 The Flamingo Boss LTD

Equipment Register and Test Record

Inspection									Test					
			Frequency							Continuity		Insulation		
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0151	AC Adaptor	N/A	Yearly	Yearly	N/A	✓	✓	✓	✓	N/A		Lim		Visual	✓
0152	" "	"	"	"	"	✓	✓	✓	✓	N/A		Lim		Visual	✓
0153	IEC lead	N/A	"	"	"	✓	✓	✓	✓	.01	✓	7200			✓
0154	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	7200			✓
0155	AC lead	"	"	"	"	✓	✓	✓	✓	N/A		7200		Vr	✓
0156	Bar light	"	"	"	"	✓	✓	✓	✓	.02	✓	7200			✓
0157	" "	"	"	"	"	✓	✓	✓	✓	.05	✓	7200			✓
0158	" "	"	"	"	"	✓	✓	✓	✓	.04	✓	7200			✓
0159	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	7200			✓
0160	" "	"	"	"	"	✓	✓	✓	✓	.08	✓	7200			✓
0161	" "	"	"	"	"	✓	✓	✓	✓	.07	✓	7200			✓
0162	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	7200			✓
0163	" "	"	"	"	"	✓	✓	✓	✓	.08	✓	7200			✓
0164	Ex lead	"	"	"	"	✓	✓	✓	✓	.03	✓	7200			✓
0165	5 meter lead	"	"	"	"	✓	✓	✓	✓	.02	✓	7200		No lable	✓
0166	" " "	"	"	"	"	✓	✓	✓	✓	.02	✓	7200		"	✓
0167	" " "	"	"	"	"	✓	✓	✓	✓	.01	✓	7200		"	✓
0168	" " "	"	"	"	"	✓	✓	✓	✓	.01	✓	7200		"	✓
0169	" " "	"	"	"	"	✓	✓	✓	✓	.02	✓	7200		"	✓
0170	" " "	"	"	"	"	✓	✓	✓	✓	.01	✓	7200		"	✓
0171	" " "	"	"	"	"	✓	✓	✓	✓	.01	✓	7200		"	✓
0172	" " "	"	"	"	"	✓	✓	✓	✓	.01	✓	7200		"	✓
0173	Ex lead	"	"	"	"	✓	✓	✓	✓	.01	✓	7200			✓
0174	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	7200			✓
0175	" "	"	"	"	"	✓	✓	✓	✓	.05	✓	7200			✓

Note: (✓) indicates pass, (X) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 30-6-2022 The Flamingo Bess Ltd

Equipment Register and Test Record

Inspection									Test						
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0176	IEC SPLITER	N/A	Yearly	Yearly	N/A	✓	✓	✓	✓	.007	✓	>200			✓
0177	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	>200			✓
0178	IEC lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0179	" "	"	"	"	"	✓	✓	✓	✓	.07	✓	>200		No lable	✓
0180	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	>200		" "	✓
0181	DMX Splitter	"	"	"	"	✓	✓	✓	✓	.06	✓	>200			✓
0182	5 metre Lead	"	"	"	"	✓	✓	✓	✓	.07	✓	>200		No lable	✓
0183	3 M lead	"	"	"	"	✓	✓	✓	✓	.04	✓	>200		" "	✓
0184	" " "	"	"	"	"	✓	✓	✓	✓	.04	✓	>200		" "	✓
0185	5 " "	"	"	"	"	✓	✓	✓	✓	.06	✓	>200		" "	✓
0186	" " "	"	"	"	"	✓	✓	✓	✓	.06	✓	>200		" "	✓
0187	" " "	"	"	"	"	✓	✓	✓	✓	.05	✓	>200		" "	✓
0188	IEC Splitter	"	"	"	"	✓	✓	✓	✓	.10	✓	>200		" "	✓
0189	" "	"	"	"	"	✓	✓	✓	✓	.09	✓	>200		" "	✓
0190	IEC lead	"	"	"	"	✓	✓	✓	✓	.05	✓	>200		" "	✓
0191	" "	"	"	"	"	✓	✓	✓	✓	.04	✓	>200		" "	✓
0192	Ex lead	"	"	"	"	✓	✓	✓	✓	.07	✓	>200		" "	✓
0193	IEC lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200		" "	✓
0194	" "	"	"	"	"	✓	✓	✓	✓	.03	✓	>200		" "	✓
0195	" "	"	"	"	"	✓	✓	✓	✓	.03	✓	>200		" "	✓
0196	" "	"	"	"	"	✓	✓	✓	✓	.03	✓	>200		" "	✓
0197	" "	"	"	"	"	✓	✓	✓	✓	.01	✓	>200		" "	✓
0198	" "	"	"	"	"	✓	✓	✓	✓	.02	✓	>200		" "	✓
0199	Ex lead	"	"	"	"	✓	✓	✓	✓	.03	✓	>200			✓
0200	" "	"	"	"	"	✓	✓	✓	✓	.06	✓	>200			✓

Note: (✓) indicates pass, (x) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 30-6-22 The Flamingo Boss Ltd

Equipment Register and Test Record

Inspection									Test						
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0201	IEC lead	Nk	Yearly	Yearly	"	✓	✓	✓	✓	·07	✓	>200			✓
0202	" "	"	"	"	"	✓	✓	✓	✓	·08	✓	>200		No lable.	✓
0203	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0204	" "	"	"	"	"	✓	✓	✓	✓	·05	✓	>200		" "	✓
0205	" "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0206	" "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0207	AC lead	"	"	"	"	✓	✓	✓	✓	N/A		>200		" "	✓
0208	IEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0209	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0210	" "	"	"	"	"	✓	✓	✓	✓	·02	✓	>200		" "	✓
0211	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0212	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0213	IEC Splitter	"	"	"	"	✓	✓	✓	✓	·06	✓	>200			✓
0214	" Lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		No lable	✓
0215	IEC lead	"	"	"	"	✓	✓	✓	✓	·02	✓	>200		" "	✓
0216	5M lead	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0217	IEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0218	" "	"	"	"	"	✓	✓	✓	✓	·07	✓	>200		" "	✓
0219	" "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0220	" "	"	"	"	"	✓	✓	✓	✓	·08	✓	>200		" "	✓
0221	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0222	" "	"	"	"	"	✓	✓	✓	✓	·07	✓	>200		No lable	✓
0223	" "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0224	Cow lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200			✓
0225	20A Cowlee	"	"	"	"	✓	✓	✓	✓	Lm		Lm		Visual	✓

Note: (✓) Indicates pass, (X) Indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.

Date 30-6-22 The Flamingo Boss LTD

Equipment Register and Test Record

Inspection									Test						
			Frequency							Continuity		Insulation			
Register No	Equipment Description	Serial No	Formal Visual Inspection	Combined Inspection and Test	Environment/Use	Socket	Plug	Flex	Body	Ω	✓	MΩ	Functional Check	Comments	Ok To Use
0226	IEC lead	N/A	Yearly	Yearly	N/A	✓	✓	✓	✓	·03	✓	>200			✓
0227	IEC Splitter	"	"	"	"	✓	✓	✓	✓	·08	✓	>200			✓
0228	5m lead	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		No lable	✓
0229	" "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0230	" "	"	"	"	"	✓	✓	✓	✓	·07	✓	>200		" "	✓
0231	IEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0232	5m "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200		" "	✓
0233	Ex lead	"	"	"	"	✓	✓	✓	✓	·06	✓	>200			✓
0234	" "	"	"	"	"	✓	✓	✓	✓	·06	✓	>200			✓
0235	IEC "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		No lable	✓
0236	IEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0237	" "	"	"	"	"	✓	✓	✓	✓	·07	✓	>200		" "	✓
0238	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0239	" "	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		" "	✓
0240	AC lead	"	"	"	"	✓	✓	✓	✓	N/A		min		Visual	✓
0241	" "	"	"	"	"	✓	✓	✓	✓	N/A		min		Visual	✓
0242	Ex lead	"	"	"	"	✓	✓	✓	—	·03	✓	>200			✓
0243	" "	"	"	"	"	✓	✓	✓	✓	·09	✓	>200			✓
0244	IEC lead	"	"	"	"	✓	✓	✓	✓	·03	✓	>200		No lable	✓
0245															
0246															
0247															
0248															
0249															
0250															

244 Items Tested by [signature] . CJR electrical Services

Note: (✓) indicates pass, (✗) indicates fail, (N/A) Not Applicable, (N/C) Not Checked, * To be completed by client.