

PAT Testing Logbook

 Job No:

 Page No: 1 of 12

Your PAT Testing Was Completed By:

Client Name: <u>Flamingo Boss Ltd</u>	Date: <u>28-6-23</u>
Client Address:	Engineer:
Equipment Make / Model:	Serial No:
	Calibration Date:

Company: <u>CSR electrical services</u>
Contact: <u>Colin REAY</u>
Phone No: <u>07340 572661</u>

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I		CLASS I & II		Extension Leads Polarity	Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage				
							Load A	Leakage mA			
0001	letter N	N/A	6-2024	✓	N/A	2200	N/A	N/A	✓	✓	
0002	" S	"	"	✓	"	2200	"	"	✓	✓	
0003	" A	"	"	✓	"	2200	"	"	✓	✓	
0004	" H	"	"	✓	"	2200	"	"	✓	✓	
0005	" B	"	"	✓	"	2200	"	"	✓	✓	
0006	" E	"	"	✓	"	2200	"	"	✓	✓	
0007	" V	"	"	✓	"	2200	"	"	✓	✓	
0008	" L	"	"	✓	"	2200	"	"	✓	✓	
0009	" B	"	"	✓	"	2200	"	"	✓	✓	
0010	" Y	"	"	✓	"	2200	"	"	✓	✓	
0011	" O	"	"	✓	"	2200	"	"	✓	✓	
0012	" O	"	"	✓	"	2200	"	"	✓	✓	
0013	Number 9	"	"	✓	"	2200	"	"	✓	✓	
0014	" 8	"	"	✓	"	2200	"	"	✓	✓	
0015	" 7	"	"	✓	"	2200	"	"	✓	✓	
0016	" 6	"	"	✓	"	2200	"	"	✓	✓	
0017	" 5	"	"	✓	"	2200	"	"	✓	✓	
0018	" 4	"	"	✓	"	2200	"	"	✓	✓	
0019	" 3	"	"	✓	"	2200	"	"	✓	✓	
0020	" 3	"	"	✓	"	2200	"	"	✓	✓	
0021	" 2	"	"	✓	"	2200	"	"	✓	✓	
0022	" 2	"	"	✓	"	2200	"	"	✓	✓	

PAT Testing Logbook

 Job No:

 Page No: 2 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: <u>28-6-23</u>	Company: <u>CSL electrical</u>
Client Address:	Engineer:	Contact:
Equipment Make / Model:	Serial No:	Calibration Date:
		Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I	CLASS I & II		Extension Leads		Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage		Polarity		
							Load A	Leakage mA			
0023	Number 1	NH	6-2024	✓	NH	7200	NH	NH	✓	✓	
0024	" 1	"	"	✓	"	7200	"	"	✓	✓	
0025	EX lead	"	"	✓	01	7200	"	"	✓	✓	
0026	" "	"	"	✓	07	7200	"	"	✓	✓	
0027	Speaker REF	"	"	✓	Lim	7200	"	"	✓	✓	
0028	" "	"	"	✓	Lim	7200	"	"	✓	✓	
0029	Magic Mirror	"	"	✓	NH	7200	"	"	✓	✓	
0030	EX LEAD	"	"	✓	15	7200	"	"	✓	✓	
0031	IEC Lead	"	"	✓	NH	7200	"	"	✓	✓	
0032	" "	"	"	✓	NH	7200	"	"	✓	✓	
0033	" "	"	"	✓	03	7200	"	"	✓	✓	
0034	AC adaptor	"	"	✓	NH	7200	"	"	✓	✓	
0035	Triple Plug	"	"	✓	01	7200	"	"	✓	✓	
0036	EX lead	"	"	✓	02	7200	"	"	✓	✓	
0037	IEC lead	"	"	✓	04	7200	"	"	✓	✓	
0038	Triple Plug	"	"	✓	02	7200	"	"	✓	✓	
0039	AC adaptor	"	"	✓	NH	7200	"	"	✓	✓	
0040	BOSE adaptor	"	"	✓	NH	Lim	"	"	Lim	✓	Visual
0041	IEC lead	"	"	✓	08	7200	"	"	✓	✓	
0042	IEC socket	"	"	✓	01	7200	"	"	✓	✓	
0043	IEC lead	"	"	✓	06	7200	"	"	✓	✓	
0044	Moore NZ TV	"	"	✓	NH	Lim	"	"	Lim	✓	Visual

PAT Testing Logbook

 Job No:

 Page No: 3 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: <u>28-6-23</u>	Company: <u>CS2 electrical</u>
Client Address:	Engineer:	Contact:
Equipment Make / Model:	Serial No:	Phone No:
Calibration Date:		

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I		CLASS I & II		Extension Leads		Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage		Polarity			
							Load A	Leakage mA				
0045	EX lead	N/A	6-2021	✓	0.04	7200	N/A	N/A	✓	✓		
0046	AC adaptor	"	"	✓	N/A	7200	"	"	✓	✓		
0047	AC lead	"	"	✓	N/A	7200	"	"	✓	✓		
0048	AC adaptor	"	"	✓	N/A	7200	"	"	✓	✓		
0049	AC lead	"	"	✓	N/A	7200	"	"	✓	✓		
0050	IEC LEAD	"	"	✓	0.19	7200	"	"	✓	✓		
0051	IEC lead	"	"	✓	0.17	7200	"	"	✓	✓		
0052	AC adaptor	"	"	✓	N/A	Lim	"	"	Lim	✓	Visual	
0053	" "	"	"	✓	N/A	Lim	"	"	"	✓	Visual	
0054	" "	"	"	✓	N/A	Lim	"	"	"	✓	Visual	
0055	IEC Plug	"	"	✓	0.07	7200	"	"	✓	✓		
0056	EX lead 10	"	"	✓	0.50	7200	"	"	✓	✓		
0057	EX lead 10	"	"	✓	0.47	7200	"	"	✓	✓		
0058	AC adaptor	"	"	✓	N/A	Lim	"	"	Lim	✓	Visual	
0059	" "	"	"	✓	N/A	Lim	"	"	Lim	✓	Visual	
0060	EX lead	"	"	✓	0.10	7200	"	"	✓	✓		
0061	AC adaptor	"	"	✓	Lim	7200	"	"	✓	✓		
0062	IEC lead	"	"	✓	Lim	7200	"	"	✓	✓		
0063	EX lead	"	"	✓	0.08	7200	"	"	✓	✓		
0064	Mixing Board	"	"	✓	0.03	7200	"	"	✓	✓		
0065	IEC lead	"	"	✓	0.02	7200	"	"	✓	✓		
0066	FAN	"	"	✓	0.18	7200	"	"	✓	✓		

PAT Testing Logbook

 Job No:

 Page No: 4 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: 28-6-23	Company: CSI Electrics
Client Address:	Engineer:	Contact:
Equipment Make / Model:	Serial No:	Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual	CLASS I		CLASS I & II		Extension Leads		Pass or Fail	Notes
					Earth Bond	Insulation	Load/Earth Leakage		Polarity	✓ or x		
							Load	Leakage				
✓ or x	Ω	MΩ	A	mA	✓ or x	✓ or x						
0067	EX lead	N/A	6-2024	✓	01	Lim	N/A	N/A	✓	✓	✓	USB'S
0068	AC/DC adaptor	"	"	✓	N/A	7200	"	"	✓	✓	✓	
0069	AC adaptor	"	"	✓	"	7200	"	"	✓	✓	✓	
0070	"	"	"	✓	"	7200	"	"	✓	✓	✓	
0071	"	"	"	✓	"	7200	"	"	✓	✓	✓	
0072	RFCSS Speaker	"	"	✓	Lim	Lim	"	"	Lim	✓	✓	Visual
0073	"	"	"	✓	"	"	"	"	"	✓	✓	"
0074	"	"	"	✓	"	"	"	"	"	✓	✓	"
0075	"	"	"	✓	"	"	"	"	"	✓	✓	"
0076	"	"	"	✓	"	"	"	"	"	✓	✓	"
0077	"	"	"	✓	"	"	"	"	"	✓	✓	"
0078	Podium 1L	"	"	✓	N/A	7200	"	"	✓	✓	✓	
0079	" 2L	"	"	✓	N/A	7200	"	"	✓	✓	✓	
0080	IEC lead	"	"	✓	03	7200	"	"	✓	✓	✓	
0081	"	"	"	✓	03	7200	"	"	✓	✓	✓	
0082	"	"	"	✓	Lim	Lim	"	"	Lim	✓	✓	Visual
0083	Gig Bar	"	"	✓	41	7200	"	"	✓	✓	✓	
0084	Speaker Yamaha	"	"	✓	04	7200	"	"	✓	✓	✓	
0085	"	"	"	✓	14	7200	"	"	✓	✓	✓	
0086	IEC lead	"	"	✓	07	7200	"	"	✓	✓	✓	
0087	" Ex lead	"	"	✓	03	7200	"	"	✓	✓	✓	
0088	LED's 7B	"	"	✓	02	7200	"	"	✓	✓	✓	

PAT Testing Logbook

 Job No:

 Page No: 5 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: 28-6-23
Client Address:	Engineer:
Equipment Make / Model:	Serial No:
	Calibration Date:

Company: <i>CSF electrical</i>
Contact:
Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual	CLASS I		CLASS I & II		Extension Leads		Pass or Fail	Notes
					Earth Bond	Insulation	Load/Earth Leakage		Polarity	✓ or x		
							Load	Leakage				
✓ or x	Ω	MΩ	A	mA	✓ or x	✓ or x						
0084	LEDJ 7B	MA	6/2024	✓	02	2200	Nil	Nil	✓	✓		
0086	" "	"	"	✓	02	2200	"	"	✓	✓		
0041	" "	"	"	✓	03	2200	"	"	✓	✓		
0092	" W	"	"	✓	03	2200	"	"	✓	✓		
0093	" W	"	"	✓	02	2200	"	"	✓	✓		
0094	" W	"	"	✓	01	2200	"	"	✓	✓		
0095	" W	"	"	✓	01	2200	"	"	✓	✓		
0096	" W	"	"	✓	03	2200	"	"	✓	✓		
0097	" W	"	"	✓	01	2200	"	"	✓	✓		
0098	IEC Lead	"	"	✓	02	2200	"	"	✓	✓		
0099	" "	"	"	✓	03	2200	"	"	✓	✓		
0100	LEDJ 7W	"	"	✓	01	2200	"	"	✓	✓		
0101	" "	"	"	✓	01	2200	"	"	✓	✓		
0102	" "	"	"	✓	01	2200	"	"	✓	✓		
0103	" "	"	"	✓	03	2200	"	"	✓	✓		
0104	SPLIT IEC	"	"	✓	14	2200	"	"	✓	✓		
0105	ER lead	"	"	✓	03	2200	"	"	✓	✓		
0106	" "	"	"	✓	02	2200	"	"	✓	✓		
0107	" "	"	"	✓	02	2200	"	"	✓	✓		
0108	ham white 2	"	"	✓	01	2200	"	"	✓	✓		
0109	" " 1	"	"	✓	02	2200	"	"	✓	✓		
0110	ADS Black 1	"	"	✓	02	2200	"	"	✓	✓		

PAT Testing Logbook

 Job No:

 Page No: 6 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: <u>23-6-23</u>
Client Address:	Engineer:
Equipment Make / Model:	Serial No:
	Calibration Date:

Company: <u>ORL electrical</u>
Contact:
Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I		CLASS I & II		Extension Leads Polarity	Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage				
							Load A	Leakage mA			
0111	ACB Block 2	N/A	6-2024	✓	0.02	>200	N/A	N/A	✓	✓	
0112	Dose Sinker 1	"	"	✓	0.01	>200	"	"	✓	✓	
0113	" " 2	"	"	✓	0.01	>200	"	"	✓	✓	
0114	DS Starcloth	"	"	✓	0.01	>200	"	"	✓	✓	
0115	IEC lead	"	"	✓	0.01	>200	"	"	✓	✓	
0116	DS Starcloth	"	"	✓	0.03	>200	"	"	✓	✓	
0117	IEC lead	"	"	✓	0.02	>200	"	"	✓	✓	
0118	EX lead	"	"	✓	0.03	>200	"	"	✓	✓	
0119	" "	"	"	✓	0.04	>200	"	"	✓	✓	
0120	UV light	"	"	✓	0.17	Lim	"	"	✓	✓	
0121	" "	"	"	✓	0.02	Lim	"	"	✓	✓	
0122	" "	"	"	✓	0.01	Lim	"	"	✓	✓	
0123	" "	"	"	✓	0.15	Lim	"	"	✓	✓	
0124	Fusion Spot 1	"	"	✓	0.15	>200	"	"	✓	✓	
0125	" " 2	"	"	✓	0.07	>200	"	"	✓	✓	
0126	" " 3	"	"	✓	0.01	>200	"	"	✓	✓	
0127	" " 4	"	"	✓	0.01	>200	"	"	✓	✓	
0128	Vortex 2	"	"	✓	0.02	>200	"	"	✓	✓	
0129	Power Con lead	"	"	✓	0.05	>200	"	"	✓	✓	
0130	Vortex 1	"	"	✓	0.02	>200	"	"	✓	✓	
0131	Power Con lead	"	"	✓	0.07	>200	"	"	✓	✓	
0132	Fusion 1w	"	"	✓	0.06	>200	"	"	✓	✓	

PAT Testing Logbook

 Job No:

 Page No: 7 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: 28-6-23	Company: SR electrical
Client Address:	Engineer:	Contact:
Equipment Make / Model:	Serial No:	Phone No:
Calibration Date:		

Asset No.	Appliance Description	Location	Re-Test Date	Visual	CLASS I		CLASS I & II		Extension Leads	Pass or Fail	Notes
					Earth Bond	Insulation	Load/Earth Leakage				
							Load	Leakage			
									✓ or x	Ω	
0133	Fusion Spot 4	Mk	6-2024	✓	001	7200	Mk	Mk	✓	✓	
0134	" " 2	"	"	"	0.01	7200	"	"	✓	✓	
0135	" " 3	"	"	"	.01	7200	"	"	✓	✓	
0136	AC adaptor	"	"	"	Mk	Lm	"	"	Lm	✓	Visual
0137	wifi adaptor	"	"	"	Mk	Lm	"	"	Lm	✓	Visual
0138	LED'S 6/3	"	"	"	.01	7200	"	"	✓	✓	
0139	IEC lead	"	"	"	.03	7200	"	"	✓	✓	
0140	" "	"	"	"	.03	7200	"	"	✓	✓	
0141	" "	"	"	"	.03	7200	"	"	✓	✓	
0142	Haze Machine	"	"	"	.13	7200	"	"	✓	✓	
0143	wifi adaptor	"	"	"	Mk	Lm	"	"	Lm	✓	Visual
0144	Strob light	"	"	"	Lm	Lm	"	"	Lm	✓	Visual
0145	Printer 3	"	"	"	.01	7200	"	"	✓	✓	
0146	" 2	"	"	"	.03	7200	"	"	✓	✓	
0147	DJ Controller	"	"	"	.06	7200	"	"	✓	✓	
0148	Printer I.	"	"	"	.01	7200	"	"	✓	✓	
0149	TV	"	"	"	Mk	7200	"	"	✓	✓	
0150	ac adaptor	"	"	"	Mk	7200	"	"	✓	✓	
0151	" "	"	"	"	Mk	7200	"	"	✓	✓	
0152	" "	"	"	"	Mk	7200	"	"	✓	✓	
0153	IEC Lead	"	"	"	.01	7200	"	"	✓	✓	
0154	" "	"	"	"	.02	7200	"	"	✓	✓	

PAT Testing Logbook

 Job No:

 Page No: 8 of 12

Your PAT Testing Was Completed By:

Client Name:	Date: 28-6-25
Client Address:	Engineer:
Equipment Make / Model:	Serial No: Calibration Date:

Company: <i>CSL electron</i>
Contact:
Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual	CLASS I		CLASS I & II		Extension Leads		Pass or Fail	Notes
					Earth Bond	Insulation	Load/Earth Leakage		Polarity	✓ or x		
							Load	Leakage				
✓ or x	Ω	MΩ			✓ or x	✓ or x						
0155	AC lead	M/K	6-2024	✓	M/K	>200	M/K	M/K	✓	✓		
0156	Bar light	"	"	✓	.04	>200	"	"	✓	✓		
0157	"	"	"	✓	.05	>200	"	"	✓	✓		
0158	"	"	"	✓	.04	>200	"	"	✓	✓		
0159	"	"	"	✓	.06	>200	"	"	✓	✓		
0160	"	"	"	✓	.09	>200	"	"	✓	✓		
0161	"	"	"	✓	.07	>200	"	"	✓	✓		
0162	"	"	"	✓	.06	>200	"	"	✓	✓		
0163	"	"	"	✓	.08	>200	"	"	✓	✓		
0164	EX Lead	"	"	✓	.02	>200	"	"	✓	✓		
0165	5 meter lead	"	"	✓	.02	>200	"	"	✓	✓	no label	
0166	"	"	"	✓	.02	>200	"	"	✓	✓		
0167	"	"	"	✓	.01	>200	"	"	✓	✓	"	
0168	"	"	"	✓	.01	>200	"	"	✓	✓	"	
0169	"	"	"	✓	.02	>200	"	"	✓	✓	"	
0170	"	"	"	✓	.01	>200	"	"	✓	✓	"	
0171	"	"	"	✓	.01	>200	"	"	✓	✓	"	
0172	"	"	"	✓	.02	>200	"	"	✓	✓	"	
0173	EX lead	"	"	✓	.01	>200	"	"	✓	✓		
0174	"	"	"	✓	.01	>200	"	"	✓	✓		
0175	"	"	"	✓	.05	>200	"	"	✓	✓		
0176	IEC Splitter	"	"	✓	.07	>200	"	"	✓	✓		

PAT Testing Logbook

 Job No:

 Page No: of

Your PAT Testing Was Completed By:

Client Name:	Date: 28-6-29
Client Address:	Engineer:
Equipment Make / Model:	Serial No:
	Calibration Date:

Company: <i>Electron</i>
Contact:
Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual	CLASS I		CLASS I & II		Extension Leads	Pass or Fail	Notes
					Earth Bond	Insulation	Load/Earth Leakage				
							✓ or x	Ω	MΩ	A	
0177	IEC Splitter	N/A	6-2024	✓	06	7200	nh	wh	✓	✓	
0178	IEC lead	"	"	✓	03	7200	"	"	✓	✓	
0179	"	"	"	✓	07	7200	"	"	✓	✓	
0180	"	"	"	✓	06	7200	"	"	✓	✓	
0181	DMX Splitter	"	"	✓	07	7200	"	"	✓	✓	
0182	5 metre lead	"	"	✓	06	7200	"	"	✓	✓	
0183	3 " "	"	"	✓	03	7200	"	"	✓	✓	
0184	" " "	"	"	✓	03	7200	"	"	✓	✓	
0185	5 " "	"	"	✓	04	7200	"	"	✓	✓	
0186	" " "	"	"	✓	06	7200	"	"	✓	✓	
0187	" " "	"	"	✓	05	7200	"	"	✓	✓	
0188	IEC Splitter	"	"	✓	04	7200	"	"	✓	✓	
0189	"	"	"	✓	08	7200	"	"	✓	✓	
0190	IEC lead	"	"	✓	03	7200	"	"	✓	✓	
0190	"	"	"	✓	04	7200	"	"	✓	✓	
0192	EC lead	"	"	✓	07	7200	"	"	✓	✓	
0193	IEC lead	"	"	✓	02	7200	"	"	✓	✓	
0194	"	"	"	✓	02	7200	"	"	✓	✓	
0195	"	"	"	✓	03	7200	"	"	✓	✓	
0196	"	"	"	✓	03	7200	"	"	✓	✓	
0197	"	"	"	✓	01	7200	"	"	✓	✓	
0198	"	"	"	✓	02	7200	"	"	✓	✓	

PAT Testing Logbook

 Job No:

 Page No: of

Your PAT Testing Was Completed By:

Client Name:	Date: 28-6-23
Client Address:	Engineer:
Equipment Make / Model:	Serial No:
	Calibration Date:

Company: <i>CSL electron</i>
Contact:
Phone No:

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I		CLASS I & II		Extension Leads Polarity	Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage				
							Load A	Leakage mA			
0199	Ex lead	N/A	6-2024	✓	03	7200	N/A	N/A	✓	✓	
0200	" "	"	"	✓	06	7200	"	"	✓	✓	
0201	IEC lead	"	"	✓	07	7200	"	"	✓	✓	
0202	" "	"	"	✓	08	7200	"	"	✓	✓	
0203	" "	"	"	✓	03	7200	"	"	✓	✓	
0204	" "	"	"	✓	05	7200	"	"	✓	✓	
0205	" "	"	"	✓	06	7200	"	"	✓	✓	
0206	" "	"	"	✓	05	7200	"	"	✓	✓	
0207	AC lead	"	"	✓	N/A	7200	"	"	✓	✓	
0208	IEC lead	"	"	✓	03	7200	"	"	✓	✓	
0209	" "	"	"	✓	03	7200	"	"	✓	✓	
0210	" "	"	"	✓	01	7200	"	"	✓	✓	
0211	" "	"	"	✓	02	7200	"	"	✓	✓	
0212	" "	"	"	✓	02	7200	"	"	✓	✓	
0213	IEC splitter	"	"	✓	05	7200	"	"	✓	✓	
0214	IEC lead	"	"	✓	02	7200	"	"	✓	✓	
0215	5m lead	"	"	✓	05	7200	"	"	✓	✓	
0216	IEC lead	"	"	✓	04	7200	"	"	✓	✓	
0217	" "	"	"	✓	05	7200	"	"	✓	✓	
0218	" "	"	"	✓	06	7200	"	"	✓	✓	
0219	" "	"	"	✓	06	7200	"	"	✓	✓	
0220	" "	"	"	✓	06	7200	"	"	✓	✓	

PAT Testing Logbook

 Job No:

 Page No: of

Your PAT Testing Was Completed By:

Client Name:	Date: 24-6-23	Company: <i>OR electrical</i>
Client Address:	Engineer:	Contact:
Equipment Make / Model:	Serial No:	Phone No:
		Calibration Date:

Asset No.	Appliance Description	Location	Re-Test Date	Visual	CLASS I		CLASS I & II		Extension Leads		Pass or Fail	Notes
					Earth Bond	Insulation	Load/Earth Leakage		Polarity	✓ or x		
							Load	Leakage				
✓ or x	Ω	MΩ	✓ or x	✓ or x								
0221	IEC lead	N/A	6-2024	✓	04	7200	N/A	N/A	✓	✓		
0223	" "	"	"	✓	07	7200	"	"	✓	✓		
0223	" "	"	"	✓	06	7200	"	"	✓	✓		
0224	CON lead	"	"	✓	03	7200	"	"	✓	✓		
0225	20 x Controller	"	"	✓	lim	lim	"	"	lim	✓	Visual	
0226	IEC lead	"	"	✓	03	7200	"	"	✓	✓		
0227	IEC Spikes	"	"	✓	08	7200	"	"	✓	✓		
0228	5 m lead	"	"	✓	06	7200	"	"	✓	✓		
0229	" "	"	"	✓	06	7200	"	"	✓	✓		
0230	" "	"	"	✓	07	7200	"	"	✓	✓		
0231	IEC lead	"	"	✓	03	7200	"	"	✓	✓		
0232	5 m lead	"	"	✓	06	7200	"	"	✓	✓		
0233	EX lead	"	"	✓	05	7200	"	"	✓	✓		
0234	" "	"	"	✓	05	7200	"	"	✓	✓		
0235	IEC lead	"	"	✓	03	7200	"	"	✓	✓		
0236	" "	"	"	✓	03	7200	"	"	✓	✓		
0237	" "	"	"	✓	07	7200	"	"	✓	✓		
0238	" "	"	"	✓	03	7200	"	"	✓	✓		
0239	" "	"	"	✓	03	7200	"	"	✓	✓		
0240	AC lead	"	"	✓	M/L	lim	"	"	lim	✓	Visual	
0241	" "	"	"	✓	M/A	lim	"	"	lim	✓	Visual	
0242	EX lead	"	"	✓	03	7200	"	"	✓	✓		

